

Test Verification of Conformity

Verification Number: 210902250SHA-V2

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

Applicant Name & Address:	Greensun Solar Energy Tech. Co., Ltd Room B-1006, Room B-1007, Woye Garden Commercial Building, No. 81 Ganquan Road, Shushan District, Hefei City, Anhui Province
Product Description:	Utility-Interactive Micro Inverter
Ratings & Principle Characteristics:	See Appendix (Specifications table)
Models/Type References:	See Appendix (Specifications table)
Brand Name:	WVC
Relevant Standards:	DIN V VDE V 0126-1-1: 2013
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2021-06-22 to 2021-08-17
Test Report Number(s):	210902250SHA-002

Additional information in Appendix.

Signature



Name: Jonny Jing
Position: Manager
Date: 2021-09-29

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 210902250SHA-V2

Manufacturer: Same as applicant

Specifications table			
Model	WVC-350W	WVC-300W	Hedy
Input:			
Vmax PV (Vdc)	60	60	100
Isc PV (absolute Max.) (A)	20	15	7
Number MPP trackers	1	1	1
Number input strings	1	1	1
Max. PV input current(A)	14	13.6	6
MPPT voltage range (Vdc)	25 to 60	25 to 60	60 to 100
Output			
Normal Voltage(V)	<input checked="" type="checkbox"/> 1/N/PE 230Vac <input type="checkbox"/> 3 φ /N/PE 230/400Vac		
Frequency (Hz)	<input checked="" type="checkbox"/> 50 Hz <input type="checkbox"/> 60Hz		
Current (Max. continuous) (A)	1.52	1.3	1.3
Power rating (W)	350	300	300
Power Rating (VA)	350	300	300
Power factor /rated	≥0.99	≥0.99	≥0.99
others			
Protective class	Class I		
Ingress protection (IP)	IP 65		
Temperature (°C)	-40°C to +50°C		
Inverter Isolation	<input type="checkbox"/> Non-isolated <input checked="" type="checkbox"/> High frequency isolated		
Oversvoltage category	OVC III (AC Main), OVC II (PV)		
Weight (kg)	0.82		
Dimensions (WxHxD) (mm)	165 x 176 x 38		

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Remark:

The products tested are incomplete in functional features or limited in performance capabilities and are intended for use and evaluation in other products. See test report for detail information.

Signature



Name: Jonny Jing
Position: Manager
Date: 2021-09-29

