

# Test Verification of Conformity

Verification Number: 210902250SHA-V1

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

Applicant Name & Address:	Greensun Solar Energy Tech. Co., Ltd Room B-1006, Room B-1007, Woye Garden Commercial Building, No. 81 Ganquan Road, Shushan District, Hefei City, Anhui Province
Product Description:	Utility-Interactive Micro Inverter
Ratings & Principle Characteristics:	See Appendix (Specifications table)
Models/Type References:	See Appendix (Specifications table)
Brand Name:	WVC
Relevant Standards:	VDE-AR-N 4105:2018 in conjunction with DIN VDE V 0124-100 :2020
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2021-06-22 to 2021-08-17
Test Report Number(s):	210902250SHA-001
Additional information in Appendix.	

## Signature



**Name: Jonny Jing**  
**Position: Manager**  
**Date: 2021-09-29**

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 210902250SHA-V1

Manufacturer: Same as applicant

Specifications table			
Model	WVC-350W	WVC-300W	Hedy
<b>Input:</b>			
Vmax PV (Vdc)	60	60	100
Isc PV (absolute Max.) (A)	20	15	7
Number MPP trackers	1	1	1
Number input strings	1	1	1
Max. PV input current(A)	14	13.6	6
MPPT voltage range (Vdc)	25 to 60	25 to 60	60 to 100
<b>Output</b>			
Normal Voltage(V)	<input checked="" type="checkbox"/> 1/N/PE 230Vac <input type="checkbox"/> 3 φ /N/PE 230/400Vac		
Frequency (Hz)	<input checked="" type="checkbox"/> 50 Hz <input type="checkbox"/> 60Hz		
Current (Max. continuous) (A)	1.52	1.3	1.3
Power rating (W)	350	300	300
Power Rating (VA)	350	300	300
Power factor /rated	≥0.99	≥0.99	≥0.99
<b>others</b>			
Protective class	Class I		
Ingress protection (IP)	IP 65		
Temperature (°C)	-40°C to +50°C		
Inverter Isolation	<input type="checkbox"/> Non-isolated <input checked="" type="checkbox"/> High frequency isolated		
Overvoltage category	OVC III (AC Main), OVC II (PV)		
Weight (kg)	0.82		
Dimensions (WxHxD) (mm)	165 x 176 x 38		

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

#### Annex E4: Verification of Conformity for power generation units

<b>Verification of Conformity for power generation units</b>	No.: 210902250SHA-V1			
<b>Manufacturer</b>	Dongguan Kaideng Energy Technology Co., Ltd. 4 th floor, Fuyuan business building, no. 1, Lane 13, xin'an maiyuan Road, Chang 'an town, Dongguan City, Guangdong, China.			
<b>Type power generation unit</b>	Utility-Interactive Micro Inverter			
<b>Model</b>	Hedy	WVC-300W	WVC-350W	
<b>Assessment values</b>	Max. active power $P_{E_{max}}$	300 W	300 W	350 W
	Max. apparent power $S_{E_{max}}$	300 VA	300 VA	350 VA
	Rated voltage	230Vac	230Vac	230Vac
<b>Rated values</b>	Rated current (AC) $I_r$	1.3 A	1.3 A	1.52
	Initial short-circuit AC current	1.3 A	1.3 A	1.55
<b>Network connection rules</b>	<b>VDE-AR-N 4105 "Power generation systems connected to the low-voltage network"</b> Technical minimum requirements for connection and parallel operation of power generation systems connected to the low voltage network			
<b>Firmware version</b>	WVC300R3-55-100-433-c3 for Hedy and WVC-300W WVC350R3-55-100-433-c3 for WVC-350W			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

### Annex E.5 Test report “Network interactions” for power generation units

Extract from the test report on the certificate of units	210902250SHA-001					
Manufacturer:	Dongguan Kaideng Energy Technology Co., Ltd. 4 th floor, Fuyuan business building, no. 1, Lane 13, xin'an maiyuan Road, Chang 'an town, Dongguan City, Guangdong, China.					
Manufacturer indications:	System type	WVC-350W				
	Max. active power $P_{E_{max}}$	350 W				
	Rated voltage	230Vac				
Measurement period	2021-06-22 to 2021-08-17					
Rapid voltage changes	N/A					
Connection without provisions (regarding the primary energy carrier)	$k_i = 0.52$					
Most adverse case when switching between generator levels	N/A					
Connection at nominal conditions (of the primary energy carrier)	$k_i = 1.02$					
Disconnection at rated power	$k_i = 1.01$					
Worst value of all switching operations	$k_{i_{max}} = 1.02$					
Flicker	Angle of network impedance $\Psi_k$ :	32°	30°	50°	70°	85°
	Long-term flicker strength $P_{It}$ :	0.26	N/A	N/A	N/A	N/A
	Initial flicker factor $c_\psi$ :	N/A	N/A	N/A	N/A	N/A

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

### E.5 Test report “Network interactions” for power generation units

(5.2.4)	TABLE: Harmonics											P
Harmonics												
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100	Limit
Order No.	I/In [%]											
2	0.00	0.08	0.25	0.47	0.38	0.28	0.20	0.21	0.17	0.23	0.34	--
3	0.01	0.08	0.09	0.09	0.08	0.09	0.17	0.11	0.19	0.20	0.21	--
4	0.00	0.10	0.09	0.03	0.03	0.05	0.14	0.17	0.15	0.16	0.15	--
5	0.01	0.43	0.68	0.84	0.83	0.89	0.90	0.89	0.92	0.99	1.06	--
6	0.00	0.02	0.11	0.08	0.09	0.09	0.11	0.14	0.17	0.20	0.21	--
7	0.00	0.09	0.10	0.24	0.27	0.26	0.28	0.27	0.31	0.38	0.46	--
8	0.00	0.02	0.05	0.03	0.05	0.07	0.07	0.09	0.08	0.07	0.04	--
9	0.00	0.01	0.08	0.06	0.07	0.09	0.09	0.08	0.09	0.10	0.10	--
10	0.00	0.04	0.04	0.05	0.04	0.02	0.09	0.10	0.04	0.04	0.10	--
11	0.00	0.02	0.05	0.06	0.12	0.13	0.14	0.12	0.14	0.15	0.17	--
12	0.00	0.01	0.02	0.02	0.03	0.04	0.03	0.02	0.02	0.02	0.02	--
13	0.00	0.01	0.02	0.01	0.04	0.05	0.06	0.06	0.08	0.10	0.11	--
14	0.00	0.04	0.10	0.12	0.09	0.04	0.06	0.09	0.06	0.06	0.07	--
15	0.00	0.01	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	--
16	0.00	0.03	0.07	0.07	0.06	0.04	0.02	0.04	0.04	0.04	0.05	--
17	0.00	0.01	0.05	0.02	0.06	0.08	0.06	0.03	0.03	0.05	0.05	--
18	0.00	0.01	0.02	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.01	--
19	0.00	0.01	0.03	0.02	0.04	0.05	0.04	0.02	0.01	0.02	0.02	--
20	0.00	0.01	0.02	0.02	0.03	0.04	0.05	0.04	0.02	0.02	0.04	--
21	0.00	0.01	0.02	0.01	0.01	0.02	0.03	0.02	0.02	0.02	0.02	--
22	0.00	0.02	0.04	0.03	0.03	0.07	0.12	0.13	0.08	0.05	0.02	--
23	0.00	0.01	0.05	0.02	0.03	0.06	0.08	0.06	0.04	0.05	0.04	--
24	0.00	0.01	0.03	0.02	0.02	0.03	0.02	0.02	0.01	0.01	0.01	--
25	0.00	0.01	0.05	0.01	0.02	0.04	0.04	0.03	0.05	0.06	0.05	--
26	0.00	0.03	0.22	0.24	0.20	0.18	0.16	0.11	0.04	0.04	0.13	--
27	0.00	0.01	0.02	0.02	0.03	0.04	0.04	0.02	0.01	0.02	0.02	--
28	0.01	0.04	0.16	0.16	0.16	0.15	0.15	0.09	0.04	0.03	0.09	--
29	0.00	0.01	0.09	0.06	0.03	0.10	0.13	0.11	0.07	0.08	0.08	--
30	0.01	0.01	0.06	0.05	0.05	0.06	0.04	0.03	0.02	0.03	0.05	--
31	0.00	0.01	0.09	0.07	0.04	0.08	0.12	0.08	0.08	0.08	0.05	--
32	0.00	0.05	0.34	0.25	0.20	0.09	0.08	0.16	0.20	0.24	0.33	--
33	0.00	0.01	0.02	0.02	0.02	0.01	0.03	0.04	0.04	0.04	0.03	--
34	0.00	0.08	0.32	0.27	0.22	0.15	0.08	0.06	0.09	0.14	0.21	--
35	0.00	0.02	0.06	0.05	0.03	0.01	0.02	0.04	0.04	0.03	0.01	--
36	0.01	0.01	0.02	0.02	0.01	0.01	0.02	0.02	0.02	0.02	0.02	--
37	0.00	0.03	0.05	0.03	0.02	0.02	0.03	0.03	0.03	0.02	0.01	--
38	0.00	0.18	0.10	0.11	0.10	0.14	0.17	0.18	0.18	0.19	0.20	--
39	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.02	0.01	0.01	0.01	--
40	0.00	0.08	0.05	0.04	0.04	0.05	0.06	0.07	0.08	0.08	0.09	--

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

(5.2.4)	TABLE: Harmonic current limit test (EN 61000-3-2)						P
Model							
Harmonic	L1		--		--		Limits -A
	Magnitude (A)	% of I	Magnitude (A)	% of I	Magnitude (A)	% of I	
02	0.00	--	--	--	--	--	1.08
03	0.00	--	--	--	--	--	2.30
04	0.00	--	--	--	--	--	0.43
05	0.02	--	--	--	--	--	1.14
06	0.00	--	--	--	--	--	0.30
07	0.01	--	--	--	--	--	0.77
08	0.00	--	--	--	--	--	0.23
09	0.00	--	--	--	--	--	0.40
10	0.00	--	--	--	--	--	0.18
11	0.00	--	--	--	--	--	0.33
12	0.00	--	--	--	--	--	0.15
13	0.00	--	--	--	--	--	0.21
14	0.00	--	--	--	--	--	0.13
15	0.00	--	--	--	--	--	0.15
16	0.00	--	--	--	--	--	0.12
17	0.00	--	--	--	--	--	0.13
18	0.00	--	--	--	--	--	0.10
19	0.00	--	--	--	--	--	0.12
20	0.00	--	--	--	--	--	0.09
21	0.00	--	--	--	--	--	0.11
22	0.00	--	--	--	--	--	0.08
23	0.00	--	--	--	--	--	0.10
24	0.00	--	--	--	--	--	0.08
25	0.00	--	--	--	--	--	0.09
26	0.00	--	--	--	--	--	0.07
27	0.00	--	--	--	--	--	0.08
28	0.00	--	--	--	--	--	0.07
29	0.00	--	--	--	--	--	0.08
30	0.00	--	--	--	--	--	0.06
31	0.00	--	--	--	--	--	0.07
32	0.00	--	--	--	--	--	0.06
33	0.00	--	--	--	--	--	0.07
34	0.00	--	--	--	--	--	0.05
35	0.00	--	--	--	--	--	0.06
36	0.00	--	--	--	--	--	0.05
37	0.00	--	--	--	--	--	0.06
38	0.00	--	--	--	--	--	0.05
39	0.00	--	--	--	--	--	0.06
40	0.00	--	--	--	--	--	0.05
THD	--	1.37	--	--	--	--	--

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## Annex E.7 Requirements to the Test Report on the NS protection

Extract from the test report for the NS protection "Determination of electric properties"		210902250SHA-001	
<b>Test report NS Protection</b>			
Type of NS protection:	Central NS protection	Further manufacturer indications	
Software version:	--		
Manufacturer:	--		
Measurement period:	--		
		Inverter(s)	
Protective function	Set value	Tripping value	Tripping value NS protection
Rise-in-voltage protection U >>	$1.25 * U_n$	--	--
Rise-in-voltage protection U >	$1.10 * U_n$	--	--
Voltage drop protection U <	$0.8 * U_n$	--	--
Voltage drop protection U <	$0.45 * U_n$	--	--
Frequency decrease protection f <	47.5Hz	--	--
Frequency increase protection f >	51.5Hz	--	--
<p><sup>a</sup> The tripping time includes the period from the limit value violation U/f until the tripping signal to the interface switch. When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above. The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms * Longest disconnection of the rise-in-voltage protection as a moving 10-minute-average.</p>			
<input type="checkbox"/> <b>For integrated NS protection</b>			
Assigned to power generation unit of type			
Type integrated interface switch			
Response time of interface switch for integrated NS protection			
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.			
NOTE1: $U_n=230V$			

Remark:

The sample<s> covered in this VOC are incomplete in functional features or limited in performance capabilities and are intended for use and evaluation in other products. See test report for detail information.

**Signature**



**Name: Jonny Jing**

**Position: Manager**

**Date: 2021-09-29**

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.